



Title: Non-Domestic Gas Safety On Site Guide (2 x Part Guide; Parts 1 and 2)				
New				
ISBN: Part 1 (978-1-83863-062-1) Part 2 (978-1-83863-063-8)	SAP: PNICNDSG24	Version No: 11 Revised	Date of Publication: September 2024	Cover Updated? Yes/No: No Sample of cover images:  
Part 1: 11 Chapters; 242 pages		Part 2: 6 Chapters; 268 pages		
Old				
ISBN: Part 1 (978-1-83863-044-7) Part 2 (978-1-83863-045-4)	SAP: PNICNDSG23	Version No: 11	Date of Publication: April 2023	
Part 1: 11 Chapters; 242 pages		Part 2: 6 Chapters; 268 pages		

General Overview of Changes:

Chapter/Clause	Amendments
<p>Editorial – Every chapter of Version 11 Revised of the Non-Domestic Gas Safety On Site Guide sees light touches associated with editorial improvements; from adding coloured tab’s to each Chapter in response to feedback from training providers, updating references that have been amended since the Guide was last published, to general readability changes to improve clarity of the information provided.</p> <p>The technical changes in this latest version of the Guide are relatively minor in nature and therefore, the Guide remains Version 11. The following technical changes have been made in the Guide -</p>	
Chapter 1; 1.1.9	Amended flammability limits for LPG in bullets 2 and 3; Propane amended from 2.2 - 10 % to 1.7 - 10.9 % and for Butane, amended from 1.8 - 9 % to 1.4 - 9.3 %. This reflects those values used in NICEIC Certification’s LPG On Site Guide, which reflects current requirements of Liquid Gas UK Codes of Practice
Chapter 1; 1.2.3	Note has been expanded to convey that the impact of IGEM/G/13 could see a reduced working pressure on the outlet of a domestic sized gas meter (no greater than a U16) from a notional 21 mbar to 18.5 mbar and a cross-reference has been added to the pertinent information within NICEIC Certification’s Domestic Gas Safety On Site Guide (Chapters 6 and 20)
Chapter 2; 2.6	Amended text regarding the UKCA/UKNI conformity mark replacing CE marking - UK government communicates that it intends to continue to recognise the CE conformity mark indefinitely alongside the UKCA/UKNI conformity marks

Continues over the page

Title: Non-Domestic Gas Safety On Site Guide (2 x Part Guide; Parts 1 and 2)

General Overview of Changes - Continued:

Chapter/Clause	Amendments
Chapter 5; Fig. 5.1	Map of UK updated to show Orkney and Shetland Islands as required by the <i>Island (Scotland) Act 2018</i>
Chapter 6; 6.4.3	A single paragraph relating to tapping low pressure pipework to install a test point has been deleted - proprietary fittings need to be used when installing appropriate purge and test points
Chapter 14; 14.8.4.1	Reference to Gas Safe Technical Bulletin (TB) 005 (A, B & C) has been deleted as the TB is withdrawn by Gas Safe Register
Chapter 14; 14.8.4.1 and Fig's 14.51 & 14.52	<p>Text amended regarding 'internal habitable areas/kitchens' as may be found in the domestic sector (i.e., those that have been enclosed by a building element such as an extension or conservatory) to reflect updated guidance in NICEIC Certification's Domestic Gas Safety On Site Guide.</p> <p>Figure 14.51 has been amended to show additional information on openings and to correct an error for Northern Ireland that previously stated 10,000 mm² background ventilation when it should have been 8,000 mm².</p> <p>Figure 14.52 is no longer required as all pertinent information is in Figure 14.51 - Figure 14.52 deleted and subsequent figure numbers and cross-references amended to reflect the change.</p>
Chapter 14; 14.11.1; Fig. 14.54 (was 14.55)	Minor amend to flow chart to remove blue box that stated 'CO ₂ levels comply with current standards' - was located right-hand side of diamond for CO ₂ readings below 2,800 ppm. This reflects current guidance of IGEM/UP/19
Chapter 14; 14.13	Text deleted regarding domestic ventilation provisions for educational establishments where more than one cooking appliance is installed and replaced with guidance that the ventilation provisions need to comply with BS 6173, including interlocking as required by IGEM/UP/19